



Product Service

Compliance Document

No. D 075386 0206 Rev. 00

Holder of Certificate: **Shenzhen Kstar New Energy Company Limited**
The 9th Floor, R&D Building
Kstar Industrial Park, Guangming Hi-tech Industrial Zone
518107 Shenzhen, Guangdong Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Converter
(Hybrid Inverter)**

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: www.tuvsud.com/ps-cert

Test report no.: 64290223105201

Date, 2023-03-20

(Billy Qiu)

Compliance Document

No. D 075386 0206 Rev. 00

Model(s): KAC50DP

Parameters:

Model	KAC50DP
PV input rating	
Input voltage range	350V~1000 Vd.c.
Input voltage range (full load)	667V~750 Vd.c.
Max. continuous input current	108 Ad.c. (36 Ad.c. per PV string)
Max. PV short circuit current	120 Ad.c. (40 Ad.c. per PV string)
Max. input power	75 kW
Battery input/output rating	
Battery type	Lithium-ion
Rated voltage	512 Vd.c.
Battery voltage range	350V~750 Vd.c.
Max. dis/charging power	55/55 kW
Max. dis/charging current	110/110 Ad.c. (55 Ad.c. per battery terminal)
Grid input/output rating	
Rated input/output active power	50 kW
Max. input/output active power	50 kW
Max. input/output apparent power	55 kVA
Rated input/output frequency	50/60 Hz
Rated input/output voltage	400 Va.c.3~PE
Rated input/output current	72 Aa.c.
Max. input/output continuous current	80 Aa.c.
Power factor	0.9 inductive(under-excited) to 0.9 capacitive(over-excited)

Tested according to:

IEC 61727:2004
IEC 62116:2014