

Compliance Document

No. D 075386 0136 Rev. 02

Holder of Certificate: **Shenzhen Kstar New Energy Company Limited**
The 9th Floor, R&D Building
Kstar Industrial Park, Guangming Hi-tech Industrial Zone
518107 Shenzhen, Guangdong Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Converter
(Hybrid Inverter)**

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: www.tuvsud.com/ps-cert

Test report no.: 64290203098903

Date, 2021-09-23



(Billy Qiu)

Compliance Document

No. D 075386 0136 Rev. 02

Model(s): **BluE-S 3680D, BluE-S 5000D,
BluE-S 3680D-M1, BluE-S 5000D-M1**

Parameters:

Model	BluE-S 3680D	BluE-S 5000D
PV terminal		
Vmax. PV	580Vd.c.	
Rate Voltage	400Vd.c.	
MPPT Voltage Range	120 ~ 550Vd.c.	
MPPT Voltage Range (full load)	184 ~ 550Vd.c.	230 ~ 550Vd.c.
MPPT Tracker number	2	
Max. continuous PV input current per tracker	13Ad.c.	
Isc PV per tracker	16Ad.c.	
Max. continuous PV input power	4800W	6500W
Battery terminal		
Battery type	Lithium or lead-acid batteries	
Voltage range	40 ~ 60Vd.c.	
Rated voltage	48Vd.c.	
Maximum charge/discharge current	50Ad.c./80Ad.c.	100Ad.c./100Ad.c.
Maximum charge/discharge power	3000W/4000W	4600W/4600W
Grid terminal parameter		
Rated voltage	230Va.c.	
Rated frequency	50Hz	
Rated input Current	20Aa.c.	
Maximum continuous input current	20Aa.c.	
Maximum continuous input power	4600VA	
Rated output Current	16Aa.c.	20Aa.c.
Maximum continuous output current	16Aa.c.	20Aa.c.
Power factor (Cos phi), adjustable	0.8 leading ~ 0.8 lagging	
Maximum continuous output power	3680VA	4600VA
Back up load terminal parameter		
Rated voltage	230Va.c.	
Rated frequency	50Hz	
Rated output Current	16Aa.c.	20Aa.c.
Maximum continuous output current	16Aa.c.	20Aa.c.
Rated continuous output power	3680W	4600W
Maximum output apparent power	4000VA	4600VA

Compliance Document

No. D 075386 0136 Rev. 02

Model	BluE-S 3680D-M1	BluE-S 5000D-M1
PV terminal		
Vmax. PV	580Vd.c.	
Rate Voltage	400Vd.c.	
MPPT Voltage Range	80 ~ 560Vd.c.	
MPPT Voltage Range (full load)	165 ~ 520Vd.c.	210 ~ 520Vd.c.
MPPT Tracker number	2	
Max. continuous PV input current per tracker	15Ad.c.	
Isc PV per tracker	18Ad.c.	
Max. continuous PV input power	4800W	6500W
Battery terminal		
Battery type	Lithium or lead-acid batteries	
Voltage range	40 ~ 60Vd.c.	
Rated voltage	48Vd.c.	
Maximum charge/discharge current	50Ad.c./80Ad.c.	100Ad.c./100Ad.c.
Maximum charge/discharge power	3000W/4000W	4600W/4600W
Grid terminal parameter		
Rated voltage	230Va.c.	
Rated frequency	50Hz	
Rated input Current	20Aa.c.	
Maximum continuous input current	20Aa.c.	
Maximum continuous input power	4600VA	
Rated output Current	16Aa.c.	20Aa.c.
Maximum continuous output current	16Aa.c.	20Aa.c.
Power factor (Cos phi), adjustable	0.8 leading ~ 0.8 lagging	
Maximum continuous output power	3680VA	4600VA
Back up load terminal parameter		
Rated voltage	230Va.c.	
Rated frequency	50Hz	
Rated output Current	16Aa.c.	20Aa.c.
Maximum continuous output current	16Aa.c.	20Aa.c.
Rated continuous output power	3680W	4600W
Maximum output apparent power	4000VA	4600VA



Compliance Document

No. D 075386 0136 Rev. 02

**Tested
according to:**

NRS 097-2-1:2017 Edition 2.1